



Email: Barbara.Lance@colliercountyfl.gov

Telephone: (239) 252-8998

Addendum 2

Date: May 31, 2018

From: Barbara Lance, Procurement Strategist

To: Interested Bidders

Subject: **Addendum #2: Solicitation # 18-7348 – Tamiami Well 18 Generator Replacement**

The following clarifications are issued as an addendum identifying the following clarification to the scope of work, changes, deletions, or additions to the original solicitation document for the referenced solicitation:

Clarifications:

Drawing E1, Keynote 7:

Add the phrase "See specifications for additional requirements".

Drawing E1, Keynote 7:

Add the phrase "Provide tank pressure testing prior to tank removal and after tank reinstallation."

Drawing E2, Keynote 7:

Add the phrase "See specifications for additional requirements".

C: Tom Sivert, Project Manager

Please sign below and return a copy of this Addendum with your submittal for the above referenced solicitation.

(Signature)

Date

(Name of Firm)