



Email: Barbara.Lance@colliercountyfl.gov

Telephone: (239) 252-8998

Addendum 2

Date: September 25, 2018

From: Barbara Lance, Procurement Strategist

To: Interested Bidders

Subject: **Addendum # 2:** Solicitation # 18-7483 SCWRF Turbo Blowers 2 & 3-Replacement of Four Turbo Blowers 306

The following clarifications are issued as an addendum identifying the following clarification to the scope of work, changes, deletions, or additions to the original solicitation document for the referenced solicitation:

Change:

Question 2:

The specified butterfly valves are not available with a flange body. Only Wafer or Lug style. Please specify which one is acceptable.

Answer:

Section 15110, Valves and Accessories, Paragraph 2.07 (B) 1 revised:

- Valves shall be DeZurik, High Performance Model BHP with ANSI Class 150 full lug ends.
- Revise the butterfly valve references on Plan Sheet 5 and 7 to reflect the use of "Lug style".

C: Pete Schalt, Project Manager

Please sign below and return a copy of this Addendum with your submittal for the above referenced solicitation.

(Signature)

Date

(Name of Firm)