

**SARASOTA COUNTY GOVERNMENT  
PROCUREMENT**  
1660 Ringling Blvd., 3<sup>rd</sup> Floor • Sarasota, Florida 34236  
Telephone 941-861-5266 • Fax 941-861-5129

BID # : #186887LC  
Newtown & Fruitville Master Lift Station Rehabilitation

**ADDENDUM NO. 1**

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the Bid. Items not referenced herein remain unchanged, including the response date.

**Part I - Pertaining to the Solicitation Package:**

N/A

**Part II – Pertaining to the Technical Specifications / Scope of Work:**

N/A

**Part III – Responses to Questions:**

Question: The RTU supplier is unfamiliar with the specified panel w/ plexiglass cover. Are they to provide the 36"x48" cabinet as a complete assembly?

Answer: Refer to Section 16475 – 2.01 (B. & C.). The Remote Terminal Unit (RTU) shall be "Duplex Model for Sarasota County" by Westerman Companies in Breman, Ohio. No other manufacturer or model shall be accepted by the County. The bidder can procure the RTU complete with the foot-mounted enclosure from Westerman Companies or may fabricate the foot-mounted enclosure required for the RTU per the specifications and drawings.


By submitting a response, offerors acknowledge receipt of any and all issued addenda, and agree to the provisions of each.

Approved by County:

  
\_\_\_\_\_  
Lori Crick, Procurement Analyst

  
\_\_\_\_\_  
Date

  
\_\_\_\_\_  
Carmen Gomez, Sr. Procurement Analyst

  
\_\_\_\_\_  
Date

  
\_\_\_\_\_  
Gene Allen, Project Manager

  
\_\_\_\_\_  
Date