

**SARASOTA COUNTY GOVERNMENT
PROCUREMENT**

1660 Ringling Blvd., 3rd Floor • Sarasota, Florida 34236
Telephone 941-861-5266 • Fax 941-861-5129

BID # : 186887LC
Newtown and Fruitville Master Lift Station Rehabilitation

ADDENDUM NO. 3

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the Bid. Items not referenced herein remain unchanged, including the response date.

Part I - Pertaining to the Solicitation Package:

N/A

Part II – Pertaining to the Technical Specifications / Scope of Work:

N/A

Part III – Responses to Questions:

1. Question: Addendum 2, question 8 answer: For further clarification, the contractor does not need to carry dollars for any work associated with the FPL service at the Newtown site? The contractor will install a disconnect switch and terminal box on a post installed by others?

Answer: The present road improvement project currently under construction includes a new FPL transformer and local meter and will be in service before this rehabilitation begins. However, it is the bidder(s) responsibility to ensure appropriate 'dollars' are included for any FPL (disconnection and/or reconnection fees) to facilitate the required rehabilitation electrical Work. It is the intent of this design that the existing panel(s) rack be used for the new service entrance breaker and automatic transfer switch.

2. Question: Addendum 2, question 9 answer: Please confirm distance from transformer provided by others to the existing rack location where the new meter will be located.

Answer: Approximately 100 feet. However, the new conduit, conductors and FPL meter will have already been installed before this rehabilitation begins, replacement or modifications to the existing service entrance will not be required for this project.

By submitting a response, offerors acknowledge receipt of any and all issued addenda, and agree to the provisions of each.

**SARASOTA COUNTY GOVERNMENT
PROCUREMENT**

1660 Ringling Blvd., 3rd Floor • Sarasota, Florida 34236
Telephone 941-861-5266 • Fax 941-861-5129

Approved by County:

Lori Crick

Lori Crick, Procurement Analyst

7/19/18

Date

CG

Carmen Gomez, Sr. Procurement Analyst

9/19/18

Date

Gene Allen

Gene Allen, Project Manager

09/19/2018

Date