



# COUNTY OF CHARLOTTE PURCHASING DIVISION

Charlotte County Administration Center  
18500 Murdock Circle  
Port Charlotte, Florida 33948-1094  
(941) 743-1378

via fax

TO: PROSPECTIVE BIDDERS

DATE: November 19, 2018

RE: ADDENDUM #4 BID NO. 2019000063 – STORMWATER CONTROL STRUCTURE HAVERHILL 4.84 WATERWAY

BID OPENING DATE: 2:00 p.m. (EST) NOVEMBER 28, 2018

Bidders are hereby notified that this Addendum shall be made a part of the documents. The intent is to add to, modify, or clarify the documents. Should any of these items have an effect on price, such changes shall be included in the price bid. These items have the same force and effect as if contained in the original.

#### ITEM #1

QUESTION #1: Plan sheet C9 calls for 20" valves to have scuffers/scrapers. This is only available in 24" and larger valves. Please advise on type of valve required.

ANSWER: Since 20" valves are not manufactured with scuffers, this requirement found on Sheet Number C9 can be deleted.

This addendum is binding and is to be considered as if contained within the original bid documents of Bid No. 2019000063. Bidders are required to acknowledge receipt of this addendum on their bid forms.

  
Kimberly A. Corbett, C.P.M., CPPB  
Senior Division Manager Purchasing

KAC/vs

cc: Karen Bliss, Project Manager  
File