



Email: Kristofer.lopez@colliercountyfl.gov
Telephone: (239)252-8944

Addendum #3

Date: April 10, 2019
From: Kristofer Lopez, Procurement Strategist
To: Interested Bidders
Subject: Addendum # 3 Solicitation #19-7568-Western Interconnect Force Main Project

Plans

1. Plan Sheet 33: Force Main Air Release Detail Additional Clarification – A 2" outlet shall be provided on the electrofusion branch saddle. Piping and valving for the 2" ARVs shall be 2" in size. For 3" ARVs, the piping shall be immediately increased to 3" from the 2" outlet.

Please sign below and return a copy of this Addendum with your submittal for the above referenced solicitation.

(Signature)

Date

(Name of Firm)