



Email: Cynthia.mccanna@colliercountyfl.gov  
Telephone: (239) 252-8992

**Addendum #2**

**Date:** November 12, 2020  
**From:** Cynthia McCanna, Procurement Strategist  
**To:** Interested Bidders  
**Subject:** Addendum # 2 Solicitation #21-7823 - 108<sup>th</sup> & 109<sup>th</sup> Avenue North Public Utilities Renewal Project

The following clarifications are issued as an addendum:

1. SFWMD Master Dewatering Permit 11-03812-W; 108<sup>th</sup> & 109<sup>th</sup> Avenue North at Naples Park
2. SFWMD Water Use Individual Permit 11-03812-W
3. Bid Schedule Revised has been uploaded
4. Measurement and Payment Section IV Revised has been uploaded
5. 108<sup>th</sup> & 109<sup>th</sup> Avenue North Project Plans Revised has been uploaded
6. Road/driveway dewatering ramps clarification:  
If road/driveway dewatering ramps are utilized at roadways/driveways, the contractor shall provide barricades on either side of the ramps to protect/warn vehicles from driving over manifolds/connection sections on either side of all ramps.
7. Private property yard drain clarification:  
Private property yard drains shall be NDS 12” Square Catch Basins (Items 1200, 1212, 1206, and 1266) or approved equal.  
<https://www.ndspro.com/PDFs/Brochures/1200NGB-Next-Generation-Catch-Basin-Brochure.pdf>
8. SFWMD dewatering commencement notification clarification:  
The Contractor shall notify the SFWMD a minimum of 5 days prior to commencing dewatering activities.

If you require additional information, please post a question on our Bid Sync ([www.bidsync.com](http://www.bidsync.com)) bidding platform under the solicitation for this project.

**Please sign below and return a copy of this Addendum with your submittal for the above referenced solicitation.**

\_\_\_\_\_  
(Signature)

\_\_\_\_\_  
Date

\_\_\_\_\_  
(Name of Firm)