



Email: Leeann.Charles@colliercountyfl.gov
Telephone: (239) 252-4270

Addendum 1

Date: June 10, 2022
From: Leeann Charles, Procurement Strategist
To: Interested Bidders
Subject: Addendum #1, 22-8002 NCWRF North and South Bleach Piping Replacement

The following changes are made to the above-mentioned Collier County solicitation:

Change 1. Correction/Clarification Section 11123 Containment Pipe System – Replace existing Specification section with new specification.

Change 2. Contract Drawings : Sheet D-1 Replace the drain assembly detail and external sensor detail on Sheet D-1 with revised details

Change 3. Clarification Contractor to provide 2 pair #16 instrumentation cable for extension of leak sensor wiring to the Control Panel at North Bleach Facility.

Change 4. Clarification The scale on sheets M-8 and M-9 are 1” for 11x17 sheets. Disregard the bar scales on these sheets.

Change 5. Extend the Q & A deadline and Bid due date.

QUESTION & ANSWER DEADLINE: ~~June 10, 2022 AT 5:00 PM~~ June 16, 2022 AT 5:00 PM

OPENING DAY/DATE/TIME: ~~June 17, 2022 AT 3:00 PM~~ June 24, 2022 AT 3:00 PM

If you require additional information, please post a question on our BidSync (www.bidsync.com) bidding platform under the solicitation for this project.

Please sign below and return a copy of this Addendum with your submittal for the above referenced solicitation.

(Signature)

Date

(Name of Firm)

