



Email: Trevor.Adaline@colliercountyfl.gov  
Telephone: (239) 252-8941

#### **Addendum #4**

**Date:** April 16, 2024  
**From:** Trevor Adaline, Procurement Strategist  
**To:** Interested Bidders  
**Subject:** Addendum #4 Solicitation #23-8194R – South County Regional Water Treatment Plant (SCRWTP) Filter Media Replacement and Blend Tank Passive Relief

The following clarifications/changes are issued as an addendum:

Words ~~struck through~~ are deleted; Words underlined are added.

#### **BidSync Question 13**

Spec Sec 46 61 11 - States that the Underdrain Manufacturer shall be on site during ALL underdrain installation activities, can you please confirm this is required. Also this says the manufacturer needs be on site during all testing per Section 3.04.C, but Section 3.03.A.2 states only (2) of each test specified (4) tests specified, please clarify which is correct?

#### **Answer – Question 13**

The manufacturer is not required to be onsite, rather, the specification states the “filter underdrain system manufacturer’s representative.” Yes, a qualified representative is specified to be onsite at specific times. However, this individual does not need to be directly employed by the manufacturer so long as the manufacturer acknowledges in writing that the individual proposed has completed any necessary training that is required to oversee and to certify that the filter components have been installed correctly and in strict accordance with the filter manufacturer’s instructions. This is often accomplished with local equipment manufacturer representative personnel.

In response to Question 13, the following change has been made.

#### **Change 1. Specifications Change – Section 46 61 11, Paragraph 3.03.A.2**

~~A manufacturer’s representative shall inspect and supervise at least 2 of each of the specified tests for a total of 6 tests.~~

A manufacturer’s representative shall inspect and supervise specified tests for the filters.

**Change 2. Q&A/Bid Due Date Extension**

The “**Q&A Deadline**” has been extended from ~~April 12, 2024~~ at 5:00 PM EST to April 19, 2024 at 5:00 PM EST.

The “**Bid End Date**” has been extended from ~~April 18, 2024~~ at 3:00 PM EST to April 25, 2024 at 3:00 PM EST.

If you require additional information, please post a question on our Bid Sync ([www.bidsync.com](http://www.bidsync.com)) bidding platform under the solicitation for this project.

**Please sign below and return a copy of this Addendum with your submittal for the above referenced solicitation.**

\_\_\_\_\_  
(Signature)

\_\_\_\_\_  
Date

\_\_\_\_\_  
(Name of Firm)