

24-8320 NCRWTP Raw Water Feedline Rehab Phase 1 and 2

SUPPLEMENTAL QUALIFICATION OF BIDDERS

Contractor shall provide **three reference projects** completed within the **last ten years** meeting the following minimum qualification:

1. Minimum of **300 linear feet of 8-inch or larger** of 316 stainless-steel pipe installation requiring disinfection prior to placement in service at a potable water treatment plant with capacity of **2 MGD or greater**.