

May 4, 2018

FLORIDA KEYS AQUEDUCT AUTHORITY  
NAVY SYSTEM UPGRADES  
WASTEWATER PUMPING SYSTEMS  
FKAA PROJECT #4072-17

**Addendum No. 2**


To All Plan Holders:

This addendum sets forth changes and/or additional information as listed below and is hereby made a part of the Specifications and Contract bid Documents for the above referenced project.

- A. Added option for use of Schedule 80 PVC at Lift Stations A-647 and A-939. Technical Specification 15012 added. Updated drawings.
- B. Added replacement of valve vault at Lift Station K-100 to scope. Technical Specifications 03401 and 05100 added. Technical Specification 01010 and 01025 updated. Updated bid schedule to include lump sum for removal and disposal of existing valve vault and installation of larger valve vault. Updated drawing.
- C. Added model of pump base plates to be replaced to drawing.
- D. Review the revised documents and submit any questions by email to [jdacey@fkaa.com](mailto:jdacey@fkaa.com) by 12:00 PM on Monday, May 7, 2018.

Acknowledgment of receipt of this addendum is required as part of the bid package, however, inclusion of a copy of this addendum is not required.

FLORIDA KEYS AQUEDUCT AUTHORITY

 5-4-18

Jolynn Reynolds, P.E.

Date