



Solicitation No.: B250213AVR

Solicitation Name: Fort Myers Shores Phase 1 D Water Main Replacement

Subject: Addendum Number 1

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

1. QUESTIONS/ANSWERS

9.	Where is the work associated with line item 21 Signing & marking? - we do not see any work scope or details
Answer	Please refer to the Technical Specifications associated to line item 21.
10.	Who is responsible to tie the new services to the existing water line to the homeowner?
Answer	The CONTRACTOR is responsible for transferring the existing customers to the new water line after FDEP clearance has been obtained.
11.	Who is responsible for supplying & installing the water meter - after the new service has been installed?
Answer	The existing water meter will be kept in placed and transfer to the new watermain when the new line have been installed and cleared to be put in operation.
12.	Will installation of the service lines under the roads by "missile" acceptable
Answer	Please refer to LCU detail W-05 for requirement for tubing under roadway.

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.

Ana Reynoso

Ana Reynoso
Procurement Analyst Direct Line: 239-533-8850
Lee County Procurement Management