



# St. Johns River

## Water Management District

Ann B. Shortelle, Ph.D., Executive Director

---

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940  
On the internet at [www.sjrwmd.com](http://www.sjrwmd.com).

DATE: August 24, 2020  
TO: Prospective Respondents  
FROM: Amy Lucey, Contracts Administrator  
SUBJECT: Addendum #3 to Invitation for Bids # 35891, S96D Rehabilitation

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your bid documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

Q1. I am requesting approval for Epoxytec CPP Sprayliner / series as an “or equal” to material section for Concrete Wet Wells and manholes that are modified requiring field-lined epoxy – Coatings Products. The attached technical data sheet has listed physical properties that provide a clear comparison in products. Epoxytec CPP Sprayliner is specifically designed for water/wastewater collections and treatment. Application of Epoxytec CPP Sprayliner is via a plural component spray equipment, from Certified Applicators; a list is available on our website, applied to a recommended 125 mils, either applied directly to properly prepared concrete lift stations or structures, can be returned to service in as little as 18 hours. In the linked design specification, page 3-4, Epoxytec has recommended resurfacing guidelines, along with case studies, technical data sheets, and design guideline specs.

A1: No. The request for substitution request is not approved

Attachments:  
Drawing Sheet C4 replacement

**NOTE:** The Bid Opening **remains** 2:00 p.m., **Tuesday, September 8, 2020**

Please acknowledge receipt of this Addendum on the **BID FORM** provided in the bid package.

If you have any questions, please e-mail me at [alucey@sjrwmd.com](mailto:alucey@sjrwmd.com).