



St. Johns River

Water Management District

Ann B. Shortelle, Ph.D., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940
On the internet at www.sjrwmd.com.

DATE: August 31, 2020
TO: Prospective Respondents
FROM: Amy Lucey, Contracts Administrator
SUBJECT: Addendum #5 to Invitation for Bids # 35891, S96D Rehabilitation

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your bid documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

- Q1: Does the blasting grit/paint chips etc. have to be removed from the area that will be coffer dam?
A1: Yes, blast media and paint chips need to be removed and properly disposed.
- Q2: Is containment required during sandblasting operations or is open air blasting approved?
A2: Open air blasting of wingwalls is acceptable. If the gate is moved to the District's rework site for rehabilitation, staff strongly recommends using an overhead tarp or cover. Blast media and paint chips also need to be removed from the rework site and properly disposed.

NOTE: The Bid Opening **remains** 2:00 p.m., **Tuesday, September 8, 2020**

Please acknowledge receipt of this Addendum on the **BID FORM** provided in the bid package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.