



October 13, 2023

**City of Plant City
Procurement Department
cpcprocurement@plantcitygov.com**

**IFB 23-042UM-TG
Lift Station 7 Replacement Project REBID**

Addendum No. 1

***Respondents are required to acknowledge this addendum in their response.**

The following is additional information, clarifications, questions, and responses related to the above referenced IFB.

Clarifications

- A pre-bid meeting and/or site visit will not be scheduled since the project site is accessible and does not require special access. Prospective bidders are welcome to visit anytime.
- The engineers estimate of probable construction cost is \$1,314,008.
- The sole bid received from the original bid, IFB 23-026UM-TG, was submitted by Benchmark Construction for 1,298,684.
- The City is not currently considering approved alternate parts, equipment, or vendors for this IFB. Prospective bidders shall supply the equipment specified in the IFB documents.

Question and Answer

Q: Does the switch for the area light go on the inside of the panel or is it mounted to the outside?

A: **The light switch shall be mounted inside the control panel.**

Q: Can a Halladay safety grading be used in lieu of a safety net?

A: **Bid should include Safety net for wet well.**

Q: Is the DFS unit to be incorporated into the Control Panel or mounted outside on the rack, in its own panel box?

A: **DFS TAC unit shall be mounted inside the control panel. Coordinate with Data Flow for installation of unit.**

Q: Is there an estimated mobilization date?

A: The estimate mobilization date will be based on City Commission approval and contract execution.

Q: Why is the project being rebid?

A: The bid received was found to be non-responsive.

Q: Could Sulzer / ABS pumps be approved to bid on the submersible pumps for this project?

A: Bid should include Vaughan E Series Chopper Pumps, Model S4L as specified.

All other requirements, terms and conditions of the IFB Document remain unchanged.