



Procurement Management Department
1500 Monroe Street 4th Floor
Fort Myers, FL 33901
Main Line: (239) 533-8881
Fax Line: (239) 485-8383
www.leegov.com/procurement

Posted Date: June 27, 2018

Solicitation No.: B180367DLK

Solicitation Name: Pine Island WWTP Effluent Pump Station Replacement

Subject: Addendum Number 1

The following represents clarification, additions, deletions, and/or modifications to the above referenced bid. This addendum shall hereafter be regarded as part of the solicitation. Items not referenced herein remain unchanged, including the response date. Words, phrases or sentences with a strikethrough represent deletions to the original solicitation. Underlined words and bolded, phrases or sentences represent additions to the original solicitation.

NOTE: FAILURE TO USE AN ADDENDUMS REVISED BID/PROPOSAL FORM SHALL DEEM BIDDER NON-RESPONSIVE.

1.	Do you have a budget or engineers estimate for this project?
Answer	<u>As per 13.3, Lee County will not reveal engineering estimates or budget amounts for a project</u> unless required by grant funding or unless it is in the best interest of the County. According to FL § 337.168: A document or electronic file revealing the official cost estimate of the department of a project is confidential and exempt from the provisions of s. 119.07(1) until the contract for the project has been executed or until the project is no longer under active consideration.
2.	The pump specification section 2.10 calls for 5 Roto-floats for pump control, and 5 floats are shown in the drawing on page 433, but page 432 calls for a submersible level transmitter and 1 Roto-float for pump control. Please clarify which is required.
Answer	<u>Use one submersible level transmitter and one Roto-float.</u>
3.	Please advise as to the approved system integrators for division 16 instrumentation and controls.
Answer	<u>Provide the services of a Lee County Utilities pre-qualified instrumentation and controls contractor for this project. The pre-approved contractors qualified through a RFQ process. This list can be found on the Procurement website at: https://www.leegov.com/procurement/awarded-annual-contracts/downloads?fid=3889&fn=Project2013-10-17T17_47_57.xml Any contractor that is not on the list will have to go through the same process as the RFQ qualified contractors, in order to be approved for this project.</u>

4.	What is the Engineer/Budget/Project Estimate for the Bid mentioned above?
Answer	Please see the answer to Question 1
5.	Can you tell me the estimated budget for the Pine Island WWTP Effluent Pump Station project?
Answer	Please see the answer to Question 1
6.	Can you please provide specifications the 8" Motorized Butterfly valves on this project?
Answer	Use 8" Pratt 2FII Motorized Butterfly valve with Beck Actuator.

BIDDER/PROPOSER IS ADVISED, YOU ARE REQUIRED TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WHEN SUBMITTING A BID/PROPOSAL. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY RESULT IN THE BIDDER/PROPOSER BEING CONSIDERED NON-RESPONSIVE.

ALL OTHER TERMS AND CONDITIONS OF THE SOLICITATION DOCUMENTS ARE AND SHALL REMAIN THE SAME.

Diana Khan

Manager
Lee County Procurement Management