

ADDENDUM NO. 1

To: Potential Proposers

Subject: Addendum No. 1 - RFQ 14-6213-121 Manatee Road Potable Water Storage Tank Upgrades

1. **Add-** “Scrap Disposal for Revenue Chain Custody” form shall be added to Specification 02220 as requirement for disposal of scrap material.
2. **Add-** To the Summary of Work- Specification 01110 and to Drawing M-4 that the County purchased the orifice plate for the existing Altitude Valve Assembly and the Contractor shall install orifice plate.
3. **Revise:** Specification 01330, 1.04I,4.
Was: Piping, valves, fittings, flange adapters, orifice plates, pipe supports and pipe appurtenances.
Revise- Piping, valves, fittings, flange adapters, pipe supports and pipe appurtenances.
4. **Drawing G-2** and Special Project Requirements.
Was- The Contractor shall coordinate and install the Owner provided position indicator solenoid valve.
Revise- The Contractor shall coordinate and connect the Owner provided position indicator and solenoid valves to termination cabinet (shown on Drawing E 3) along with coordination of the installation of the Owner provided orifice plate.
5. Drawing M-4:
Was- New 12” 316 SS Orifice Plate by Bermad w/6.25” Diameter Orifice & EPDM Gasket.
Revise- New 12” 304 SS Orifice Plate by Bermad w/6.25” Diameter Orifice (To be supplied by the County and installed by the Contractor) & EPDM Gasket.
6. Site visit can be arranged by contacting Dustin Grossenbaugh at 239.465.1402.