



ADDENDUM #2

Date: July 13, 2021

To: Interested Bidders

From: Lourdes Santiago

Subject: RFQ 20-7800 Mahogany Bend Drive Force Main Extension (Fiddlers Creek)

This addendum is being issued to include the following:

Change #1 - The following Question was received by email:

Question #1: *We received information from a vendor that the spec'd DR25 will not likely be produced or be available, and asked for us to address this with the County before the project bids. They advised it may be worthwhile to replace the spec'd 600LF of DR25 with DR18, so we do not run into issues when the project moves forward.*

Answer #1: *Considering that currently Contractors are seeing limited to no availability of larger diameter pipe supplies (DR 25) as noted in Question #1, we recommend changing the 600 feet of DR 25 to DR 18 because it is more readily available. If something changes and DR 25 becomes more readily available as the project gets underway then a deduct could be taken.*

Change #2 - The revised Bid Form is attached.

If you require additional information please provide all questions to Lourdes.Santiago@colliercountyfl.gov by Wednesday, July 14, 2021 at 3:00 pm. Answers to the questions will be provided via email to all vendors.

C: Evelyn Colon

Please sign below and return a copy of this Addendum with your submittal for the above referenced solicitation.

(Signature)

Date

(Name of Firm)